

Schematic ECO-HK / PK with solar

Basic Lambda-Touchtronic with boiler-, return- and outside temperature sensor; control of the accumulator loading pump and return mixer with accumulator or low loss header; with the add-on control board A, one mixer-controlled heat circuit and one HWS circuit can be connected; FR35/40 possible through CAN-Bus; Additional extension with one extension module HKM.2 through CAN-Bus; Per HKM, 2 heat circuits and 1 HWS circuit can be connected.
PSP 4: for Hargassner layered accumulators and 2 sensors, on pump for loading and emptying and forced acc. loading; ATTENTION: Sensors need to be ordered separately!

ATTENTION:
The boiler specific parameter changes are carried out in the installer level settings.

